

# Office of The Chief Medical Officer, Ghaziabad

Ref.No. DSO/IDSP/2026/ 2060

Dated:- 06-04-2026

## WATER TEST REPORT

ADDRESS:- PARAMHANS PUBLIC SCHOOL, SEC-23, SANJAY NAGAR, GHAZIABAD.

PREVIOUS SAMPLE COLLECTION DATE	SAMPLE COLLECTION AREA	SAMPLE WATER WAS BEING USED	SAMPLE ID	RESULT
N/A	N/A	N/A	N/A	N/A

No of sample collected : 01

SAMPLE COLLECTION DATE	SAMPLE COLLECTION AREA	SAMPLE WATER WAS BEING USED	SAMPLE ID	RESULT
04-04-2026	RO WATER	DRINKING	6907	Satisfactory

### Test Result

H<sub>2</sub>S Water test kit : Negative (-Ve) after 24-48 hrs incubation


### Comments: -


H<sub>2</sub>S water test kit report - ve reflects that water is free from Coliforms Organism.


### Recommendation:


Given water safe for drinking purpose.

- This Satisfactory report/result is issued with the condition that the water quality will be maintained in future otherwise, it will automatically stand cancelled on proof.
- Validity upto one year.

  
Lab Technician  
DPHL Lab  
Ghaziabad

  
Microbiologist  
DPHL Lab  
Ghaziabad

  
Epidemiologist  
IDSP  
Ghaziabad

  
District Surveillance Officer/  
District Public Health Expert  
Ghaziabad  
District Surveillance Officer  
District Public Health Expert  
District Ghaziabad